

From: Jill Fisher
Sent: 28 September 2015 10:00
To: Cllr Onnalee Cubitt
Subject: FW: Questions for The Environment Agency and Thames Water on the River Loddon and Water Quality

Dear Cllr Cubitt,
Please see the email from Thames Water as requested.
Best regards
Jill

From: Mark Mathews
Sent: 25 September 2015 08:00
To: Joanne Brombley
Cc: Joan Forteath; drwilson
Subject: RE: Questions for The Environment Agency and Thames Water on the River Loddon and Water Quality

**** PLEASE NOTE: This message has originated from a source external to Basingstoke & Deane Borough Council, and has been scanned for viruses. Basingstoke and Deane Borough Council reserves the right to store and monitor e-mails ****

**** PLEASE NOTE: This message has originated from a source external to Basingstoke & Deane Borough Council, and has been scanned for viruses. Basingstoke and Deane Borough Council reserves the right to store and monitor e-mails ****

Hi Joanne,

I have the following response.

'We can confirm that the latest phosphate reading for September was 0.420mg/l and for August was 0.470mg/l. The consent limit is 1mg/l.'

I trust this clarifies matters.

Cheers

Mark Mathews
Town Planning Manager
Thames Water